

FIBERWEB  
CLARK/HAMMERBEAM CORPORATION  
PO BOX 381, DEDHAM, MA 02027  
TEL# 781-461-1946 FAX# 781-461-1314 WEBSITE: [www.fiberwebflashing.com](http://www.fiberwebflashing.com)

## **SECTION 076526**

### **SELF ADHERING SHEET FLASHING**

This guide specification can be used to specify **AQUA FLASH PREMIUM**, a self adhering waterproofing membrane comprised of woven polyethylene film coated with a clear environmentally friendly adhesive engineered to provide moisture protection in cavity wall and frame construction. This product specification can be inserted in SECTION 04800- MASONRY ASSEMBLIES. This guide may be used either in conjunction with other guides or separately for SECTION 71300- SHEET WATERPROOFING , SECTION 076500 - FLEXIBLE FLASHINGS or (04090.4- SELF- ADHERING CAVITY WALL MEMBRANE).

#### **PART 1 – GENERAL**

##### **1.1 SUMMARY**

- A. Section includes: Self adhering waterproofing membrane and primer to provide moisture protection in masonry cavity wall construction and frame construction.

##### **1.2 REFERENCES**

- A. ASTM E96 – Test Methods for Water Transmission of Materials
- B. ASTM D412 – Test Methods For Vulcanized Rubber And Thermoplastic Rubbers and Thermoplastic Elastomers – Tension
- C. ASTM D903 – Peel Or Stripping Strength of Adhesive Bonds

##### **1.3 SUBMITTALS**

- A. Provide in accordance with Section 01330- Submittal Procedures
  - 1. Product Data and Installation Instructions
  - 2. (MSDS) Material Safety Data Sheets
  - 3. 2 inch by 2 inch minimum membrane sample

##### **1.4 PRODUCT HANDLING**

- A. Storage - Protect product from inclement weather or excessive heat
- B. Temperature not to exceed 150 degrees or go below 25 degrees Fahrenheit

FIBERWEB  
CLARK/HAMMERBEAM CORP.  
TEL/781-461-1946

## **PARTS 2 – PRODUCTS**

### **2.1 ACCEPTABLE MANUFACTURERS**

- A.** CLARK/HAMMERBEAM Corp., PO Box 381, Dedham, MA 02027; Tel/781-461-1946;  
[www.fiberwebflashing.com](http://www.fiberwebflashing.com)
- B.** Manufacturers of equivalent products submitted and approved in accordance with Section 01630-  
Product Substitution Procedures

### **2.2 PRODUCTS**

- A.** A self-adhering waterproofing membrane with a siliconized release liner; AQUA FLASH PREMIUM as manufactured by FIBERWEB Div. CLARK- HAMMERBEAM Corp.).
  1. Composition: a clear, VOC free adhesive bonded to a heavy duty woven polyethylene film
  2. Total thickness: 40 mils
  3. Widths: 12”, 16”, 18”, 24”, 36” (select appropriate width)
  4. Ultra Violet Exposure: 2,000 hrs. – no change
  5. Peel Adhesion of Adhesive Bonds: 10.25 lbs.lf/in. in accordance with ASTM D903
  6. Moisture Vapor Transmission: .02 grains max/sq.ft./hr. in HG in accordance with ASTM E96
  7. Tensile Strength: 6018 psi in accordance with ASTM D412C
  8. Elongation: 20% in accordance with ASTM D412C
  9. Water Absorption: 1% in accordance with ASTM D570
- B.** Primer: To be used for substrate preparation as recommended by waterproofing membrane manufacturer

## **PART 3 EXECUTION**

### **3.3. INSPECTION**

- A.** Concrete substrate must be fully cured prior to membrane application
- B.** Substrate is to be reasonably smooth, free from any loose material, debris, oils and is to be completely dry

### **3.4 PREPARATION**

- A.** Prepare substrate surface in accordance with manufacturers recommendations
- B.** Primer Application
  - 1. Follow manufacturer's recommendations

### **3.5 MEMBRANE APPLICATION**

- A.** Cut membrane into 8-10 foot lengths
- B.** Remove release liner. Apply membrane starting from the lowest point and work upwards.
- C.** All laps are 2 ½" inch minimum
- D.** Use a steel hand roller to secure membrane firmly in place eliminating wrinkles and air pockets
- E.** Cut membrane flush with outside surface of building when no drip plate is installed
- F.** Inside and outside corners must be covered with two layers of membrane and sealed with mastic (see details/drawings)

**END OF SECTION**